



**KOMO®**  
Product certificate  
**K66915/03**



Issued 2020-01-01 Replaces K66915/02  
Valid until Indefinite Dated 2017-07-01  
Page 1 of 2

Multilayer pipes  
**APE Raccorderie**

This product certificate is issued on the basis of BRL BRL 5610 "Plastics piping systems of PE-X/Al intended for heating installations: radiator connections" issued on 25 October 2016 by Kiwa, conform the Kiwa-Regulations for Certification.

The quality system and product characteristics in association with Multilayer pipes are assessed periodically.

On this basis Kiwa declares that a justified confidence exists, that Multilayer pipes delivered by the certificate holder at delivery fulfil:

- the technical specification laid down in this product certificate,
  - the product requirements as laid down in this product certificate and in the BRL
- provided that Multilayer pipes have been marked with the KOMO®-mark in a manner as indicated in this product certificate;

Ronald Karel  
Kiwa

*The certificate is listed in the overview on the website of Stichting KOMO: [www.komo.nl](http://www.komo.nl).*

*This product certificate is only valid in combination with a KOMO certified plastics piping system*

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Holder of Certificate**

APE Raccorderie  
Via Gozzano 8  
25068 SAREZZO  
Italy  
Tel. +39 03089 20912  
Fax +39 03082 6624  
[info@ape-raccorderie.com](mailto:info@ape-raccorderie.com)  
[www.ape-raccorderie.com](http://www.ape-raccorderie.com)



Evaluated is:  
quality system  
product  
Periodic inspection

## Multilayer pipes

---

### TECHNICAL SPECIFICATION

#### Subject

Multilayer pipes

#### Product characteristics

The product complies to BRL 5610 Plastics piping systems of PE-X/Al intended for heating installations: radiator connections.

#### Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)	Wall thickness Aluminium (mm)
16	2,0	0,2
20	2,0	0,3
26	3,0	0,4
32	3,0	0,45

Colour: outside: white  
inside: naturel

#### Marking

The products shall be marked with the KOMO<sup>®</sup> mark.

#### Pipes

The minimum required marking on the pipes shall be:

- KOMO (or KOMO<sup>®</sup> word mark) + class 5/ 10 bar;
- material identification: PE-Xb;
- the build up of the pipe; PE-Xb/Al/PE-Xb;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meters.

#### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### APPLICATION AND USE

The products are intended to be used for piping systems for heating installations: radiator connections and floor heating systems with a lifetime of 50 years at an operating temperature profile according to class 5 of ISO 10508 and an allowable working pressure of maximum 10 bar.

### RECOMMENDATION FOR THE CUSTOMER

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

if you should reject a delivery on the basis of the above, please contact:

- APE Raccorderie

and, if necessary:

- Kiwa Nederland B.V.

For the proper storage, transport and processing consult the instructions of the certificate holder.



Multilayer pipes

---

