



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8231CN0175

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	APE Raccorderie S.r.l. Via Gozzano 8 Ponte Zanano, I-25068 Sarezzo (BS)
Distributor <i>Vertreiber</i>	APE Raccorderie S.r.l. Via Gozzano 8 Ponte Zanano, I-25068 Sarezzo (BS)
Product Category <i>Produktart</i>	Composite tubes for drinking water installations: PE-Xb/Al/PE-Xb tube, manufacturing group 1 (8231)
Product description <i>Produktbezeichnung</i>	Multilayer pipe (PE-Xb/Al/PE-Xb) for the drinking water installation
Model <i>Modell</i>	APE Multylayer
Test reports <i>Prüfberichte</i>	Supplement test: LC 25437 from 15.10.2025 (KIW) Supplement test: LC 20679 from 07.11.2022 (KIW) Type testing: 100401493-1 from 02.07.2012 (KIW)
Test basis <i>Prüfgrundlagen</i>	DVGW W 542 (01.08.2009)

Date of Expiry / File No. 02.07.2027 / 25-0909-WNR
Ablaufdatum / Aktenzeichen

70028-04-A-DE

07.01.2026 Swd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

A. W. Z.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvlgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
APE Multylayer	Manufacturing group: 1	diameters: up to 63 mm

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

tested diameters:

16 x 2,0 mm (AI: 0,18 mm)

20 x 2,0 mm (AI: 0,20 mm)

20 x 2,0 mm (AI: 0,28 mm)

26 x 3,0 mm (AI: 0,38 mm)

32 x 3,0 mm (AI: 0,45 mm)

40 x 3,5 mm (AI: 0,50 mm)

50 x 4,0 mm (AI: 0,60 mm)

63 x 4,5 mm (AI: 0,90 mm)

The suitability for drinking water hygiene is verified by a "Hygiene Conformity Certificate" in accordance with the currently valid legal basis.

The logo for DVGW CERT, featuring a stylized flame or leaf symbol above the text 'DVGW' and 'CERT' separated by a horizontal line.